



Evaluation Listing CCMC 03330-L

MASTERFORMAT: 05 12 00.02
Issued: 1982-12-17
Re-evaluated: 2011-11-15
Re-evaluation due: 2014-05-12

Adjustable JP Post

1. Evaluation

Conforms to CAN/CGSB-7.2-97. The maximum allowable load is 38.06 kN at a maximum length of 2438 mm.

2. Description

A Type 1, adjustable, telescopic, double-tubed steel column comprised of an inner section with an outer diameter of 63.2 mm and a wall thickness of 2.97 mm, and an outer section of 70.1 mm and a wall thickness of 2.64 mm. On top of the column is a screw jacking unit measuring 22.4 mm in diameter. The slotted support pin is 19.05 mm in diameter and the top and bottom bearing plates are 89 mm x 152 mm x 6.4 mm thick. The maximum extension of the column is 2438 mm.

3. Standard and Regulatory Information

See the [Preface](#) and the standard for explanation.

Listing Holder: Renown Specialties Company Ltd.
221 Racco Parkway
Thornhill, ON L4J 8X9
Tel: 905-669-6955
Fax: 905-669-1563

Plant(s): Thornhill, ON

This Listing is issued by the Canadian Construction Materials Centre, a program of the Institute for Research in Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.

Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to <http://www.nrc-cnrc.gc.ca/eng/services/irc/ccmc.html>, or contact the Canadian Construction Materials Centre, Institute for Research in Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.